

No. 19045

Date 11/11/2025

To

The Principal,
PM Shri. Govt. Senior Secondary School,
Shahabad (M)
School Code-2411.

Subject: - Regarding Issue of building Safety Certificate of PM Shri Govt. Senior Secondary School, Shahabad (M) in district Kurukshetra for the Year 2025-26.

Reference: - Your School letter No. 1714 dated 03.11.2025.

In this connection, it is intimated that the building cited as subject has been inspected by the Sub Divisional Engineer, Provincial Sub Division No.1, PWD B&R Br., Shahabad (M) along with concerned JE-in-Charge and found that above-mentioned building seems to be safe as per visual inspection. Accordingly, the Building Safety Certificate has been issued for the year 2025-26.

DA/Annexure-D


EXECUTIVE ENGINEER

Endst. No./CB

Dated

Copy is forwarded to the Sub Division Engineer, Provincial Sub Division No.1, PWD B&R Br., Shahabad (M) for information and necessary action. This is W.R.T. his office Letter No. 1903 dated 10.11.2025

DA/Nil


EXECUTIVE ENGINEER

Annexure D

BUILDING SAFETY CERTIFICATE

No.

Dated: 07/11/2025

It is certified that the existing building ..P.M. SHRI GOVT. SR. SEC. School, SHAHABAD (M.) 2411 KI (name of the building or premises) at ..SHAHABAD (M.) 2411, KURUKSHETRA

Near Hockey Stadium..... (address) is having block(s)/Floor(s) as per details below:

Detail of Block(s) in school	Block (1) towards Railway	Block (2) Hockey towards	Block (3) Centre	Block (4) Left of towards GRT Road	Block (5) Right of towards GRT Road	Block (6) Office
No. of Floor(s) in the Block	1	1	1	2	2	1

The building is owned/occupied by ..P.M. SHRI GOVT. SR. SEC. School (name of the Institution) have complied with the Building safety requirements in accordance with National Building code Rules, and verified by the officers concerned of ..PWD [B&R] (Name of Department/ Govt.) on 07/11/2025 (date of inspection) in the presence of ..LAXMI PARSAD Principal P.M. SHRI GOVT. SR. SEC. School (name and addresses of the Manager/Secretary or his representative) and that the building/premises is fit for occupancy for running school with effect from 07/11/2025 for a period of ..One years in accordance with rule and subject to compliance of the specific conditions as appended.

1. Minor Crack in buldy which need to Rectify
2. Stair chare is not in good condition advised to close it for students
3. Require putty at some patches.
4. Roof Require cleaning some grasses removed uprooting on Roof.

Issued on at by

* Strike out whichever is not applicable. In case of block is more than six use separate form for detail.

Sub Divisional Engineer
Provincial Sub Division No.1,
PWD B&R Br. Shahabad (M.)

Signature with Seal : Executive Engineer, Provincial Division No.11

Name : PWD B&R Br. Kurukshetra
SH. AMIT MAHLA

Designation : EXECUTIVE ENGINEER

Name & Address of Department/ Office: PWD B&R P-II
KURUKSHETRA